

ON ORIGINAL
0 5 10 20 30 40 50m

© COPYRIGHT OF THIS DRAWING IS RESERVED BY DBFL CONSULTING ENGINEERS. NO PART SHALL BE REPRODUCED OR TRANSMITTED WITHOUT THEIR WRITTEN PERMISSION.


NO CHANGES OF WHATSOEVER NATURE ARE TO BE MADE TO ANY DETAILS SET OUT OR CONTAINED IN ANY DBFL SPECIFICATIONS OR DRAWINGS UNLESS THE EXPRESS CONSENT HAS BEEN OBTAINED IN ADVANCE IN WRITING FROM DBFL.

NOTICE: WORKS SHALL BE CONSTRUCTED IN ACCORDANCE WITH THE WORKS REQUIREMENTS.


2. ALL DIMENSIONS ARE IN METERS UNLESS SPECIFIED OTHERWISE. DO NOT SCALE FROM DRAWING
3. ALL CO-ORDINATES ARE TO IRISH TRANSVERSE MERCATOR (ITM)
4. ALL LEVELS ARE TO ORDNANCE DATUM (MALIN HEAD)
5. ALL DRAWINGS TO BE READ IN CONJUNCTION WITH THE WORKS REQUIREMENTS AND SPECIFICATIONS AND SUPPORTING DRAWINGS SERIES
6. ALL TEMPORARY TRAFFIC MANAGEMENT SHALL COMPLY FULLY WITH THE WORKS REQUIREMENTS - REFER APPENDIX 11/17 OF THE CONTRACT SPECIFICATION
7. ALL VEHICULAR, PEDESTRIAN & CYCLE ROUTES AND ACCESSES WITHIN AND SURROUNDING THE WORKS EXTENTS MUST BE MAINTAINED THROUGHOUT THE WORKS IN ACCORDANCE WITH THE CONTRACTORS APPROVED TEMPORARY TRAFFIC & OPERATIONS MANAGEMENT PLAN.

DRAWING SPECIFIC NOTES:

1. ALL FOUL SEWERS, RISING MAINS, MANHOLES AND CONNECTIONS TO BE CONSTRUCTED IN ACCORDANCE WITH IRISH WATER CODE OF PRACTICE FOR WASTEWATER INFRASTRUCTURE AND IRISH WATER WASTEWATER INFRASTRUCTURE STANDARD DETAILS. REFER TO SPECIFICATION APPENDIX 5/1 FOR FURTHER DETAILS.
2. ALL SURFACE WATER SEWERS, CONNECTIONS, MANHOLES AND GULLIES TO BE CONSTRUCTED IN ACCORDANCE WITH SPECIFICATION APPENDIX 5/1.
3. ALL EXISTING GULLY LEADS AND SEWERS SHALL BE JETTED CLEAR FOR FUTURE USE WHETHER ADJUSTED, REPLACED OR RE-TAINED.
4. LOCATION AND INVERT LEVELS OF EXISTING MANHOLES OR OUTFALL POINTS, WHERE APPLICABLE TO BE VERIFIED BY CONTRACTOR PRIOR TO COMMENCEMENT OF DRAINAGE WORKS.
5. ALL COVERS AND FRAMES TO BE CLASS D400 TO IS EN 124. 150MM MINIMUM FRAME DEPTH. REFER TO SPECIFICATION APPENDIX 5/1 FOR FURTHER DETAILS.
6. ALL WATERMANS VALVES AND FITTINGS SHALL BE CONSTRUCTED IN ACCORDANCE WITH THE IRISH WATER STANDARD DETAILS AND IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE. REFER TO APPENDIX 2/11 FOR FURTHER DETAILS.
7. MARKER POSTS AND PLATES ARE TO BE PROVIDED IN ACCORDANCE WITH IRISH WATER STANDARD DETAIL STD-W-27.
8. CONNECTION TO EXISTING WATERMANS TO BE COORDINATED BY THE CONTRACTOR WITH IRISH WATER AND/OR THE LOCAL AUTHORITY.
9. REFER TO SPECIFICATION APPENDIX 7/2 FOR DETAILS OF REINSTATEMENT OF EXISTING ROADS.
10. EXISTING AND PROPOSED DRAINAGE NETWORKS WITHIN SCHEME EXTENTS TO BE JETTED CLEAR FOLLOWING COMPLETION OF DRAINAGE WORKS AND CCTV SURVEY TO BE UNDERTAKEN AND PROVIDED TO THE EMPLOYERS REPRESENTATIVE.
11. DRAINAGE DRAWINGS SHOULD BE READ IN CONJUNCTION WITH DRAINAGE LONG SECTIONS AND SCHEDULES.



ATTENUATION AREA POND 1 SECTION A-A
SCALE: 1:200



ATTENUATION AREA POND 1 SECTION B-B
SCALE: 1:200

0	20/11/2023	ISSUED FOR PLANNING	KMM	JPC
rev	date	description	by	chkd.
STATUS CODES				
purpose	acceptance			
P3 - PLANNING PERMISSION	S - ISSUED			
 DBFL Consulting Engineers Civil, Structural & Transportation Engineering www.dbfl.ie				
DUBLIN OFFICE: Ormond House, Upper Ormond Quay, Dublin 7, D07 W704 PHONE: +353 1 400 4000 CORK OFFICE: 14 South Mall, Cork, T12 CT91 PHONE: +353 21 2024538 WATERFORD OFFICE: Suite 10 The Atrium, Maritime Gate, Canada Street, Waterford, X91 W028 PHONE: +353 51 309 500				
project ref.				
CIVIC OFFICES				
drawing title				
ATTENUATION DETAILS				
client				
MONAGHAN COUNTY COUNCIL				
designed by	author	scale	sheet size	
KM	RC	1:500	A1	
drawing no.	revision			
220084-RY-05-Z00-XXX-DR-DBFL-CE-5304	0			